



**OPTIONAL
ACCESSORIES:**

IP RATING:	IP66 & IP68 (100 metres - 7 Days), Type 4X & DTS01:1991
OPERATING TEMP:	-60°C to +135°C
MATERIALS:	Brass or Stainless Steel
PLATING:	Electroless Nickel
COMPOUND:	Peppers T-1000 Sealing Compound

CABLE GLAND SELECTION TABLE
(ALL DIMENSIONS IN mm)

NOTES

- Peppers Cable Glands Limited will not be held responsible for clients' installations where this has not been taken into account.
- When selecting IP Washer material for use with glands, please be aware of the accessories temperature range to ensure they are suitable for the intended installation.
- The gland is supplied with the correct amount of the two-part compound, gloves and instructions to allow one complete termination.
- Where approval in addition to ATEX, IECEx and CSA is required, this must be clearly requested at time of enquiry / order.**

Ex db : Ex eb : Ex nR : Ex ta : IP66 : IP68 : Class I Div 2

PART NUMBERS:

CE ENEC IECEx EAC Ex

PRODUCT DESCRIPTION

"CR-S'M" type glands, used in any orientation, are certified Flameproof Ex db, Increased Safety Ex eb, Restricted Breathing Ex nR and Dust Protected Ex ta. They are suitable for use in Group I Mining, Zone 1 and 2 for Gas Groups IIA, IIB and IIC and additionally for use in Zones 20, 21 and 22 for Dust Groups IIIA, IIIB and IIIC. Commonly referred to as a "Conduit Stopper Box", they are suitable for use with conductors carried in conduit or as a line bushing for terminating flying leads. They provide a compound barrier Ex db & IP seal on the cable inner cores, eliminating damage to cables that exhibit "cold flow" characteristics. The unique features include Peppers T-1000, the sealing compound that enables a quick and easy installation and an innovative barrier chamber that allows for a full inspection of the compound fill. The gland maintains IP66 & IP68 to 100 metres and is deluge proof without the use of an additional seal or deluge boot. It is supplied with an IP O-ring seal as standard on metric entry threads. The gland is supplied with a male conduit connection thread.

COMPLIANCE STANDARDS:

EN 60079-0, EN 60079-1, EN 60079-7, EN 60079-15, EN 60079-31,
IEC 60079-0, IEC 60079-1, IEC 60079-7, IEC 60079-15, IEC 60079-31 & IEC 60529
C22.2 (see certificate), CAN/CSA 60079-0/1/7, UL50

CERTIFICATION No:

ATEX	SIRA 03ATEX1479X & SIRA 09ATEX4124X
IECEX	IECEX SIR 07.0098X
CEC - Canada	CSA 1356011
EAC	RU C-GB.BH02.B.00693-18
INMETRO - Brazil	NCC 13.2188 X
SAC - China	NEPSI GYJ16.1401X
UKRAINE	CU 18.0322 X
CCoE - India	PESO P365300/4 & P365300/10
KCS - Korea	15-GA4BO-0665X & 15-GA4BO-0666X
ABS	14-LD463991A-1-PDA
LLOYD'S	10/00056(E1)
RMRS	14.02755.315

CURING TIME:

@ 21°C Conductor termination can be effected after 1 hour. Compound chamber can be fully inspected after 4 hours and the equipment then energised.